



Mr. Darren Robinson
Design Flooring international ltd
Crab Apple Way Vale Park
Evesham
GB-WR11 1GP WORCESTERSHIRE
VERENIGD KONINKRIJK

Your message - reference

-

our reference

PW/857

Gent

2020-04-06

Certification report 20/857

1. Description of the flooring:

Product family	Designflooring 4 Luxury vinyl tile PVC backing
Total mass	3360 g/m ² - 7470 g/m ²
Total thickness	2.0 mm – 4.5 mm
Thickness wear layer	0.3 mm – 0.7 mm (PU-acrylate)

2. Test results:

Classification according to EN 13501-1:2007+A1 (2009)

Class	EN ISO 11925-2 or CWFT (EN 14041 - 2004)	EN ISO 9239-1 (30 min.)
B _{fl}	E _{fl}	heat flux ≥ 8.0 kW/m ²

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 70 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • **IBAN •** BE 44 2100 4729 6545 • **BIC •** GEBABEBB

**addressee**

Design Flooring international ltd

our reference

PW/857

Gent

2020-04-06

page

2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

loose-laid tested on a non-combustible substrate¹

Bfl - s1

Related commercial names to this product group	LooseLay Van Gogh HDC 2.5 Palio Gluedown Palio Gluedown 2.5mm Monet
The obtained classification is based on the next test reports	Centexbel: 20.00055.02 dd 2020-01-24 Centexbel: 20.00055.03 dd 2020-01-24 Centexbel: 20.00055.08 dd 2020-01-24
Validity of the certificate	2025-01-24

Petra Wittevrongel
Product Certifier

¹ End use substrates of classes A1 or A2-s1,d0 (ISO 13238:2010 § 5.2.2)